

**REF NO: 054/2024/PMID/MCWAP2/RFB NOTICE 32**

26 APRIL 2024

***ABSTRACTION WORKS, PUMPING STATIONS, RESERVOIRS, PIPELINE, RELATED  
MULTIDISCIPLINE WORKS, ANCILLARY WORKS***

Dear Bidder,

TCTA acknowledges receipt of the requests for clarification listed in the attached table. The response to each request for clarification is provided in the attached table.

Yours faithfully

---

Azwi Nelwamondo

Senior Manager: Supply Chain Management

NO.	REQUESTS FOR CLARIFICATION	TCTA RESPONSES
1	<p>Specification 40.12.1, page 15 of 36 refers to “Attached Link Planner Profile”. The same profile report is referenced in drawing 2A-E5-004, under note 2.</p> <p>The above-mentioned document cannot be found in the documentation package. Please forward accordingly.</p>	<p>The omission is noted, and the Link Planner Profile Report is provided under addendum #11:          “Project MCWAP2_Radio_Path_Profile LINKPlanner PTP Proposal Report 12 June 2020”</p>
2	<ol style="list-style-type: none"> <li>1) The BoQ., in MS-Excel.</li> <li>2) The CP-Design Technical Report, of this project.</li> <li>3) Details of the CP-QAQC/Inspectorate, Monitoring and Professional – firm?</li> <li>4) The Project Civil Construction – Attendance Register.</li> </ol>	<ol style="list-style-type: none"> <li>1) Included in the published tender on <a href="https://www.etenders.gov.za//Home?myTab=1#">https://www.etenders.gov.za//Home?myTab=1#</a></li> <li>2) CP/AC is not a contractor’s design. All the required information required for tender purposes is covered in the specifications, BoQ and drawings. The CP design/installation will be optimised on a progressive basis during construction based on the results of the detailed soil resistivity survey and the CP monitoring results, both of which are covered in the provisional sums.</li> <li>3) Please note that all queries are to be directed to <a href="mailto:tenders01@tcta.co.za">tenders01@tcta.co.za</a></li> <li>4) Because of Protection of Personal Information Act (POPIA) such cannot be shared.</li> </ol>